



CITY OF KENNER

OFFICE OF FINANCE

E. "BEN" ZAHN III
MAYOR

ELIZABETH HERRING
INTERIM DIRECTOR OF FINANCE

POSTED

MARCH 30, 2021

ADDENDUM 1
RFQ NO. 21-6595
TO PROVIDE PROFESSIONAL SERVICES FOR
ST. JUDE SEWER LIFT STATION UPGRADES
FOR THE CITY OF KENNER

THE FOLLOWING ARE QUESTIONS PRESENTED:

Q1: On page 4 of the RFQ it says the fee is \$71,000. Is this the fee for design or construction? What is the budget for construction? If the fee is for design, is it inclusive of surveying?

A1: The fee of \$71,000 stated in the RFQ is for design phase services inclusive of surveying, preliminary and final design. This fee does not include bidding and construction phase services. The project is partially funded by an EPA Lake Pontchartrain Restoration Program Grant which only includes topographic surveying, preliminary and final design as stated in the RFQ. Funding for construction has not yet been identified.

Q2: Can you provide the exact location of the project site?

A2: The St. Jude Sewer Lift Station is located on Loyola Drive between West Esplanade Avenue and Vintage Drive. The lift station is in the median of Loyola Drive and is directly across from The Lakes of Chateau Estates apartments. See below picture.



Q3: What is the approximate size and flow rate? What is the diameter of the wet well?

A3: The existing flow rate is approximately 620 gpm. The new pumps will need to be sized appropriately for new development in the area. The wet well is approximately 25' x 12' x 15'D.

Q4: In addition to the SF 255, are sub-consultants required to submit the following: Certificate of Submission, Corporate Resolution, and Affidavit?

A4: The Certificate of Submission, Corporate Resolution and Affidavit is not required to be submitted for sub-consultants.

Q5: Can you supply a current word document for the SF 255 form?

A5: The word document of the SF 255 form was uploaded to the City of Kenner's website and Central Auction House.

END OF ADDENDUM 1