

**WASTEWATER DEPARTMENT STATUS REPORT
APRIL 2022
COUNCIL DISTRICT NO. 1
QSCEND**

COUNCIL DISTRICT	ADDRESS	REQUIRED ACTION	STATUS	QSCEND ENTRY DATE BY WASTEWATER PERSONNEL	COMPLETION DATE
1	205 Auburn	The City's gravity sewer lateral line needs to be repaired at 10.2 linear feet from the 6-inch cleanout to remove a FEMA trailer adapter.	Open/In progress	3/29/2022	
1	3000 Panama	The City's gravity sewer service line needs to be repaired. There is a possible three-way wye connection that needs to be checked for a leak.	Open/In progress	3/28/2022	
1	805 Industry	The City's gravity sewer service line needs to be repaired at the 45° turn in the pipe.	Open/In progress	3/21/2022	
1	814 Rev. Richard Wilson	The City's gravity sewer main line needs to be televised to locate the service connection.	Open/In progress	3/3/2022	
1	31st St at Loyola	Manhole No. 02201014 needs to be repaired.	Open/In progress	2/22/2022	
1	320 Duke	The service connection for this address needs to be located.	Open/In progress	2/22/2022	
1	Emerson (Dartmouth to Loyola)	The City's gravity sewer main line needs to be televised to check the condition.	Open/In progress	1/20/2022	
1	3100 Jasper	The City's gravity sewer service line needs to be repaired. The service line is separating from the main stack at 26 linear feet from the 6-inch cleanout.	Open/In progress	1/5/2022	
1	2845 Kingston	Manhole No. 03404006 needs to be repaired.	Open/In progress	11/15/2021	
1	140 Bonner	The City's gravity sewer main line needs to be repaired at 224.7 linear feet from the upstream manhole.	Open/In progress	10/20/2021	

**WASTEWATER DEPARTMENT STATUS REPORT
APRIL 2022
COUNCIL DISTRICT NO. 1
QSCEND**

COUNCIL DISTRICT	ADDRESS	REQUIRED ACTION	STATUS	QSCEND ENTRY DATE BY WASTEWATER PERSONNEL	COMPLETION DATE
1	804 Veterans	The City's gravity sewer service line needs to be televised to check for internal damage.	Open/In progress	10/25/2021	
1	509 Daniel	The City's gravity sewer service line needs to be repaired at the 6-inch wye connection.	Open/In progress	10/4/2021	
1	416 Felix	The City's gravity sewer service line needs to be repaired at 19 linear feet from the 6-inch cleanout to remove roots. The cleanout stand pipe needs to be repaired.	Closed	3/16/2022	4/11/2022
1	3137 Washington	The City's gravity sewer main line needs to be televised to locate the service connection for this address and the lot next door. The service connection enters the main line at 159.3 linear feet from the upstream manhole. No defects were observed. The total distance televised was 300.5 linear feet.	Closed	3/17/2022	8/6/2021
1	3152 Utah	The City's gravity sewer main line needs to be televised to locate the service connection. The service connection enters the main line at 6.9 linear feet from the upstream manhole. No defects were observed. The total distance televised was 295.5 linear feet.	Closed	4/5/2022	4/13/2022
1	715 - 717 Compromise	The resident requested that we determine if the red reflector that was installed in his yard could be removed. The crewman determined that this was not a utility line marker and could be removed.	Closed	4/13/2022	4/4/2022