

**WASTEWATER DEPARTMENT STATUS REPORT
APRIL 2022
COUNCIL DISTRICT NO. 2
QSCEND**

COUNCIL DISTRICT	ADDRESS	REQUIRED ACTION	STATUS	QSCEND ENTRY DATE BY WASTEWATER PERSONNEL	COMPLETION DATE
2	2344 Maine	The 6-inch cleanout stand pipe needs to be repaired due to root intrusion.	Open/In progress	4/29/2022	
2	2512 Delaware	The City's gravity sewer service line needs to be televised to check the condition.	Open/In progress	4/14/2022	
2	3711 Arkansas	Manhole No. 02124012 needs to be repaired.	Open/In progress	3/29/2022	
2	3309 Colorado	The City's gravity sewer service line needs to be televised to check the condition.	Open/In progress	3/28/2022	
2	2901 Maryland	The City's gravity sewer main line needs to be repaired at the first joint.	Open/In progress	3/28/2022	
2	3512 Arizona	The City's gravity sewer main line needs to be televised to check the condition.	Open/In progress	3/17/2022	
2	3740 Arizona	The City's gravity sewer main line needs to be televised to check the condition.	Open/In progress	3/17/2022	
2	2220-2230 Airline	Manhole No. 01073055 needs to be exposed.	Open/In progress	3/14/2022	
2	3037 Roosevelt	The City's gravity sewer service line needs to be repaired at 6.1 linear feet from the 6-inch cleanout.	Open/In progress	3/14/2022	
2	9th and Oxley	Manhole No. 01063123 needs to be repaired.	Open/In progress	3/14/2022	
2	1401 Roosevelt	A service connection needs to be installed for new construction.	Open/In progress	2/8/2022	

**WASTEWATER DEPARTMENT STATUS REPORT
APRIL 2022
COUNCIL DISTRICT NO. 2
QSCEND**

COUNCIL DISTRICT	ADDRESS	REQUIRED ACTION	STATUS	QSCEND ENTRY DATE BY WASTEWATER PERSONNEL	COMPLETION DATE
2	3501 California	The City's gravity sewer main line needs to be televised to check for an obstruction.	Open/In progress	1/18/2022	
2	3501 California	The City's gravity sewer service line needs to be televised to check for an obstruction.	Open/In progress	1/18/2022	
2	1014 Clay	The City's gravity sewer service line needs to be repaired as well as the 6-inch cleanout stand pipe.	Open/In progress	1/18/2022	
2	3141-3145 Kentucky	The 6-inch cleanout and stand pipe need to be repaired.	Open/In progress	1/18/2022	
2	1502 Clay	The 6-inch cleanout stand pipe needs to be repaired.	Open/In progress	1/14/2022	
2	1700 13th	The 6-inch cleanout stand pipe needs to be repaired.	Open/In progress	12/16/2021	
2	2404 Connecticut	The City's gravity sewer service line needs to be televised to check for a break. The plumber stated that he felt a break when he was snaking the customer's private 4-inch sewer line.	Open/In progress	10/25/2021	
2	2405 21st	The City's gravity sewer main line needs to be repaired at 90 linear feet from the upstream manhole.	Open/In progress	10/20/2021	
2	3103 Georgia	The City's gravity sewer service line needs to be repaired at 4.1 linear feet from the gravity sewer main line.	Open/In progress	10/4/2021	

**WASTEWATER DEPARTMENT STATUS REPORT
APRIL 2022
COUNCIL DISTRICT NO. 2
QSCEND**

COUNCIL DISTRICT	ADDRESS	REQUIRED ACTION	STATUS	QSCEND ENTRY DATE BY WASTEWATER PERSONNEL	COMPLETION DATE
2	3140 Iowa	The City's gravity sewer service line needs to be televised to check the condition. No defects were observed.	Closed	11/10/2021	11/10/2021
2	3601 - 3603 Arkansas	The City's gravity sewer main line needs to be smoke tested to check for defects and illegal connections.	Closed	3/17/2022	4/20/2022
2	3740 Arizona	Manhole No. 02124004 needs to be repaired.	Closed	3/17/2022	4/2/2022
2	3701 Arkansas	Manhole No. 02124011 needs to be repaired.	Closed	3/17/2022	4/3/2022
2	3512 Arizona	Manhole No. 02124007 needs to be repaired.	Closed	3/17/2022	4/3/2022
2	2901 Maryland	Manhole No. 03323021 needs to be repaired.	Closed	3/28/2022	4/2/2022
2	1108 Clay	The service connection needs to be located for a FEMA trailer.	Closed	4/5/2022	3/31/2022
2	3720 Arizona	Manhole No. 02124003 needs to be repaired.	Closed	4/7/2022	4/3/2022
2	3205 Arkansas	The 33rd and Connecticut force main air release valve manhole was damaged by grass cutters and needs to be repaired.	Closed	4/11/2022	4/8/2022
2	3418 Connecticut	Manhole No. 336S5006 needs to be repaired.	Closed	4/11/2022	4/10/2022
2	3100 Illinois	The City's gravity sewer main line needs to be smoke tested to check for defects and illegal connections.	Closed	4/18/2022	4/20/2022
2	3244 Kentucky	The sinkholes need to be dye tested. Dye was observed entering Manhole No. 03334018 and entering the storm drain.	Closed	4/25/2022	4/28/2022